



**OFFICE OF THE EXECUTIVE ENGINEER GANGA JAL PROJECT UNIT,  
U.P. JAL NIGAM (URBAN) 120 MLD W.T.P. LABORATORY,  
PRATAP VIHAR, GHAZIABAD-201009**

Letter No. 684 /

312-25T / 72

Dated 08/05/2025

To,  
Manager  
Indrapuram Public School  
6, Nyay Khand- 1, Indrapuram  
Ghaziabad.

Sub :- Physical and Chemical analysis of water sample


Dear Sir

The water analysis report for the water sample (01 No.) sent along with your letter No. IPSI /ADM /2025-26/64 Dated 06.05.2025 the physical and chemical analysis report is enclosed with this letter.


Tap Water Sample From Indrapuram Public School :- 1 No.  
6, Nyay Khand -1, Indrapuram, Ghaziabad.

Total :- 1 No.

Enclosers : As Above.

  
Executive Engineer

  
MANAGER  
Indrapuram Public School  
6, Nyay Khand-1, Indrapuram  
Ghaziabad-201012

  
DR. ASHISH MITTAL  
PRINCIPAL  
*Indrapuram*  
Public School  
6, Nyay Khand-1, Indrapuram,  
Ghaziabad - 201012. Ph : 88820 24545



# 120 MLD WATER TREATMENT PLANT LAB U.P. JAL NIGAM, GHAZIABAD

TRNo. 002135

Letter No.- 684 / Testing 1 72

Dated : 08/05/2025

## DRINKING WATER ANALYSIS REPORT

Sample Sealed : Yes  
Name of person Collected Sample : Sh. Bharat  
Date & Time of Sample Collection : 06.05.2025  
Particulars/Source of Sample : Tap Water Sample From Indirapuram Public School  
6, Nyay Khand -1, Indirapuram, Ghaziabad.  
Date of receipt of sample at Lab : 06.05.2025  
Sender Ref. No. : IPSI /ADM /2025-26/64 Dated 06.05.2025  
By : Manager  
Indirapuram Public School  
6, Nyay Khand -1, Indirapuram, Ghaziabad.

Laboratory analysis Ref. No. : PC-3889 Date: 08.05.2025

### Test Results: Physico-Chemical Characteristics As per IS 10500 : 2012 as Amendment No. 2

Sl.No.	Characteristic	Expressed as	Analysed result	Acceptable limit	Permissible limit
1	2	3	4	5	6
1	Turbidity	NTU	0.27	1	5
2	pH	-	6.89	6.5 to 8.5	No relaxation
3	Total Dissolved Solids	mg/l	29.20	500	2000
4	Total Hardness (as CaCO <sub>3</sub> )	mg/l	10.00	200	600
5	Chloride (as Cl)	mg/l	7.99	250	1000
6	Sulphate (as SO <sub>4</sub> )	mg/l	6.00	200	400
7	Fluoride (as F)	mg/l	BDL	1.0	1.5
8	Nitrate (as NO <sub>3</sub> )	mg/l	BDL	45	No relaxation
9	Calcium (as Ca)	mg/l	3.20	75	200
10	Magnesium (as Mg)	mg/l	0.48	30	100
11	Iron (as Fe)	mg/l	BDL	1.0	No relaxation
12	Residual Chlorine	mg/l	Nil	0.2	1.0

- Note :- (i) Figures in Col-5 are the limits up to which drinking water is acceptable to the consumers.  
(ii) Figures in excess of Col-6 render the water not acceptable, but still may be tolerated ( up to the limit indicated in the Col-6) in the absence of alternative and better source.  
(iii) The water sample is not collected by us.  
(iv) BDL- Below Detection Limit.

Test Conducted By

*Athm*

( For M/S Pooja Construction Co.)

COUNTER SIGNED BY

*J. E.*

J. E.

A.E.

Executive Engineer

*[Signature]*

MANAGER

Indirapuram Public School  
6, Nyay Khand-1, Indirapuram  
Ghaziabad - 201012

DR. ASHISH MITTAL  
PRINCIPAL

*[Signature]*  
Indirapuram  
Public School

6, Nyay Khand-1, Indirapuram,

Office of The Project Manager, Ganga Jal Project Unit  
U.P. Jal Nigam, Pratap Vihar, Ghaziabad

Ghaziabad - 201012, Ph : 88820 24545  
indirapuramps@gmail.com

# कार्यालय वसुन्धरा जोन गाजियाबाद नगर निगम

पत्रांक 394 / जोन-वसुन्धरा / स्वा0 / 2025

दिनांक:- 21.5.2025

## प्रमाण पत्र

प्रमाणित किया जाता है कि इन्दिरापुरम पब्लिक स्कूल, इन्दिरापुरम, गाजियाबाद स्कूल का आज दिनांक 21.05.2025 को निरीक्षण किया गया। निरीक्षण के दौरान उक्त स्कूल की सफाई व्यवस्था एवं शौचालय व मूत्रालय आदि की व्यवस्था तथा स्कूल की कक्षाओं का वेंटीलेशन तथा पेयजल की व्यवस्था दूरस्त पायी गयी है तथा भविष्य में भी मानक के अनुसार उपरोक्त कम में व्यवस्था बनाये रखेंगे। इस शर्त के साथ ठोस अपशिष्ट प्रबन्धन अधिनियम 2016 तथा उत्तर प्रदेश प्लास्टिक और अन्य जीव अनाश्रित कूड़ा-कचरा (विनिमय) 2000 का अनुपालन सुनिश्चित करेंगे। संलग्न शर्तों के कम में अनापत्ति प्रमाण वित्तीय वर्ष 2024-2025 हेतु जारी किया जाता है।

सफाई एवं स्वच्छता निरीक्षण  
वसुन्धरा जोन

  
MANAGER  
Indrapuram Public School  
6, Nyay Khand-1, Indrapuram  
Ghaziabad-201012

  
DR. ASHISH MITTAL  
PRINCIPAL  
Indrapuram  
Public School  
6, Nyay Khand-1, Indrapuram,  
Ghaziabad - 201012, Ph : 88820 24545  
indrapuramps@gmail.com